



SWEDISH TYPE APPROVAL 0318

WITH DECISION ON PRODUCTION CONTROL

KEYWORD: Tap water
Pipeline etc.

BBR 6:62

Holder: LK Pex AB

Box 21. 523 21 Ulricehamn

Tel: +46 (0)321-278 30

Fax: +46 (0)321-278 39

E-mail: info@lkpex.se

Webb: <http://www.lkpex.se>

Product name: LK Universal pipe PE-X

Pipelines of crosslinked polyethylene (PE-X) with external oxygen barrier according to standard DIN 4726. The pipes are available in the following dimensions (outside diameter x thickness in mm): 10x1.8, 12x2.0, 15x2.5, 16x2.2 (X 16), 18x2.5, 20x2.8 (X 20), 22x3.0, 25x3.5 (X 25), 28x4.0, 32x4.4, 40x5.5, 50x6.9 and 63x8.6.

Intended use

PE-X pipes for distribution of hot and cold tap water or heating in the building where highest occurring operating pressure does not exceed 1.0 MPa and where the water momentarily does not exceed 95 ° C or continuously does not exceed 70°C.

Approval

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Installations for tap water	6:62
Design	6:625

For the intended use the products meets the following requirements of PBL. Regulations governing the technical properties of materials. products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

- 3. Protection with regard to hygiene, health and environment
- 4. Safety in use

Appendix 1: Associated documents	2017-02-10
Appendix 2: Product marking	2017-02-10
Appendix 3: Control	2017-02-10
Appendix 4: Basis for approval	2017-02-10

Certifikat

Kiwa Sverige AB
Campus Gräsvik 1
SE-371 75 Karlskrona

Tel +46 (0)455-30 56 00
Fax +46 (0)455-104 36
bygg@kiwa.se
www.kiwa.se



Date of decision: 2017-02-10

Ref. no.: 721/16

Valid until: 2022-02-09

Previous ref. no.: 171/12

Kiwa Sverige AB

Magnus Jerlmark
Technical manager

Deo Yamabo
Project leader